

Memo No:- 108

Date:- 27/02/2025

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : SNP/03908/2/2025 / Private	Sample Details	Date & Time
Sender : G D GOENKA INTERNATIONAL SCHOOL	Collected By	SONIA
Location : , BAHALGARH KHEWRA ROAD SONEPAT	Collection Date	18/02/2025 at 13:38
Sample Description : Drinking Water	Received at lab	18/02/2025 at 14:15
Latitude / Longitude : 77.140776 / 28.974625	Analysis Start Date	18/02/2025
	Analysis End Date	19/02/2025
	Sample Quantity	2 ltrs

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.59	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) : 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) : 2018
4	Color	5.0	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120-B
5	Total Dissolved Solids @ 180°C ± 2°C	89	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCo3	64	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	9.62	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	9.72	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 Mg B
9	Total Alkalinity	48	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	12.99	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	6	200 mg/lit.	400 mg/lit.	USEPA / APHA 24th -4500 SO4-E
12	Fluoride as F	0.10	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C/
13	Iron as Fe	0.00	1.0 mg/lit.	1.0 mg/lit.	USEPA
14	Nitrate as No3	0.0	45 mg/lit.	45 mg/lit.	APHA 24th Edition -4500 NO3 D
15	pH @ 25°C	6.96	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition 4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED SONIPAT Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "**CONFORMING**" to Limits set in BIS10500:2012 for the tested parameters.




Sample analyzed by :

DEEPIKA ,CHEMIST
DISTRICT WATER TESTING LABORATORY,SONIPAT
email:-chemist.sonepat@phedharyana.gov.in

Health Department , Haryana (Sonipat)

O/o Civil Surgeon, Sonipat



No -Dy.CS (H) :- 26/97

Date :- 12/5/26

It is G. D. Goenka International School, Khewra, Sonipat inspected by Nodal Officer (Hygiene) and Health Inspector Safe drinking water, hygienic & sanitation conditions were found satisfactory.

Previous Number- 25/7 dated 16-04-2025

The above valid for one year – May, 2027


Deputy Civil Surgeon
Dy. Civil Surgeon
Sonipat